

Certificat UE de Conformité

EU Declaration of Conformity



Société/Company : CITEL

Adresse/ Address : 2, rue Troyon 92310, Sèvres, France

Marque/ Trade Mark : CITEL

Gamme de produits : Parafoudre Type 1 + 2 pour réseau photovoltaïque DC

Product Range : **Type 1 + 2 SPD for DC photovoltaic network**

<i>Références/Models</i>	<i>Utilisation / Application</i>
DS50PV-880G/10KT1	Type 1+2 SPD for 880 Vdc PV network
DS50PVS-880G/10KT1	Type 1+2 SPD for 880 Vdc PV network (with remote signal)
DS50PV-1000G/10KT1	Type 1+2 SPD for 1000 Vdc PV network
DS50PVS-1000G/10KT1	Type 1+2 SPD for 1000 Vdc PV network (with remote signal)
DS50VGPV-1000G/10KT1	Type 1+2 SPD for 1000 Vdc PV network
DS50VG PVS-1000G/10KT1	Type 1+2 SPD for 1000 Vdc PV network (with remote signal)
DS50PV-1000G/12KT1	Type 1+2 SPD for 1000 Vdc PV network
DS50PVS-1000G/12KT1	Type 1+2 SPD for 1000 Vdc PV network (with remote signal)
DS50PV-1500/12KT1	Type 1+2 SPD for 1500 Vdc PV network
DS50PVS-1500/12KT1	Type 1+2 SPD for 1500 Vdc PV network (with remote signal)

Cette déclaration de conformité est établie sous la seule responsabilité du fabricant.

Basé sur l'évaluation volontaire d'échantillons de produits et sur les dossiers techniques correspondants, nous certifions que les produits listés ci-dessus satisfont aux dispositions de la **Directive Basse Tension 2014/35/EU** du Conseil de l'Union Européenne et sont conformes aux normes suivantes :

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Based on voluntary assessment of the product samples and technical file, We certify that the listed products, as mentioned above, comply with the provisions of the **Low Voltage Directive 2014/35/EU** of the Council of the European Union and are conformed by compliance with following European standards:

<i>European standard</i>	<i>Description</i>
EN 50539-11:2013 + EN50539-11:2013/A1:2014	Low-voltage surge protective devices – Part 11: Surge protective devices connected to photovoltaic DC power systems – Requirements and test methods.

Sèvres,
18/02/2018



Christian Macanda

Product Manager

CITEL 2 CP S.A.S.
Capital 5 013 500 €
2 rue Troyon
92316 SEVRES CEDEX
Tél. : 01 41 23 50 23
Fax : 01 41 23 50 09
Siren 387 740 095 - APE 2712Z