



Product Service

CERTIFICATE

No. B 11 06 77124 006

Holder of Certificate: **Shanghai Citel Electronics Co., Ltd.**
499, Kangyi Road, Kangqiao Industrial Zone, Pudong
201315 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Production Facility(ies): 77124

Certification Mark:



Product: **Surge protection equipment
Surge protective device**

Model(s): **DLA-48D3**

Parameters:

Max. continuous operating voltage (Uc):	53V
Nominal discharge current (In):	5kA
Max. discharge current (Imax):	20kA
Voltage protection level (Up):	70V
Degree of protection:	IP20

Tested according to: EN 61643-21/ A1:2009
IEC 61643-21/A1:2008

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704101151104-00

Date, 2011-06-08  (Roy Yongjun Xue)

Page 1 of 1

