



Ref. Certif. No.

HU-002048

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device (SPD)

Name and address of the applicant

Citel
2 rue Troyon, 92316 Sèvres CEDEX,
France

Name and address of the manufacturer

Shanghai Citel Electronics Co., Ltd.
499 Kangyi Road, Kang Qiao Industrial Zone, Pudong,
Shanghai 201315, P.R. China

Name and address of the factory

Shanghai Citel Electronics Co., Ltd.
499 Kangyi Road, Kang Qiao Industrial Zone, Pudong,
Shanghai 201315, P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uc=320V AC; Un=230~277V AC; In=10kA for class II;
Uoc=10kV for class III; Imax=10kA; Isccr=10kA;
T2 and T3; ≤1.5/1.5kV for MLPX1-230L* series, ≤1.5kV
for MLPX2-230L* series; for indoor use only
(See Test Report for further ratings)

Trademark (if any))

CITEL

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

MLPX1-230L-W; MLPX1-230L-W/IP20;
MLPX2-230L-W; MLPX2-230L-W/IP20

Additional information (if necessary may also be reported on page 2)


A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

17061534B

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Date: 2017-09-05

Signature:

Gabor Kassai

