

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Surge Protective Device
Name and address of the applicant	SHANGHAI CITEL ELECTRONICS CO., LTD 499, Kangyi Road, Kang Qiao Industrial Zone, Pudong, Shanghai 201315, China
Name and address of the manufacturer	SHANGHAI CITEL ELECTRONICS CO., LTD 499, Kangyi Road, Kang Qiao Industrial Zone, Pudong, Shanghai 201315, China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 SHANGHAI CITEL ELECTRONICS CO., LTD 499, Kangyi Road, Kang Qiao Industrial Zone, Pudong, Shanghai 201315, China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Uc: 320 V~, IP20, Isccr: 1000 A, IL: 10 A; T2 In: 5 kA, I <sub>max</sub> : 10 kA, T3 Uoc: 10 kV; DSL P1-230L: Up: 1,5 kV (L-N, L-PE, N-PE); DSL P2-230L: Up: 1,5 kV (L-N)
Trademark (if any)	CITEL
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	DSL P1-230L, DSL P2-230L
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6036741.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2018-08-24

Signature: Kate Xu